

# Test Report

## DEGRE OF PROTECTION

Tested according to NEMA 250-2014 1<sup>st</sup> Edition, Type 3R, 4X, 12

Type of test object: Multi Cable/Pipe Transit  
Type: RGP and RGPO  
Manufacturer: MCT Brattberg AB  
Arrival date of EUT: 7 November 2018 and 14 February 2019  
Test Date: 19 November – 28 November 2018 and 19 February 2019  
Manufacturer: MCT Brattberg AB, Lyckeåborg  
SE-371 92 Karlskrona  
Sweden

### Conclusion after hosedown and gasket tests for types 3R, 4X and 12:

PASS

Kista, 26 February 2019

Intertek Semko AB  
Environmental testing

Tested by



Robert Söderqvist

Approved by



Daniel Pimenov

*This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program. ©2019*