

TEST REPORT**IEC 60529****Degrees of protection provided by enclosures (IP Code)**

Report reference No. : 1814340STO-001

Compiled by (+ signature)..... : Robert Söderqvist

Approved by (+ signature)..... : Daniel Pimenov

Date of issue..... : 28 August 2018

Contents : 16 pages

Testing laboratory

Name : Intertek Semko AB

Address : Torshamnsgatan 43, SE-164 22 Kista, Sweden

Testing location..... : As above

Test date..... : 23 – 28 August

Client

Name : MCT Brattberg AB

Address : Lyckeåborg, 371 92 Karlskrona, Sweden

Contact person : Ola Fagerberg

Test specification

Standard : IEC 60529: Edition 2.2, 2013-08

Specified IP-code : IP65 / IP66 / IP67 / IP68

Equipment Under Test (EUT)

Type of test object : Multi Cable/Pipe Transit

Arrival date of EUT : 15 August 2018

Model/Article No : RGS, RGB and RGG

S/N : -

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program. ©2018

General description:

Multi Cable/Pipe Transit tested for IP65, IP66, IP67 and IP68.

MCT Brattberg AB Multi Cable/Pipe Transit system of type RGS, RGB and RGG. The system consists of a frame, spare blocks, standard blocks, U-blocks, Add blocks, HandiBlocks, stayplates, STG/PTG.

Investigation for ingress of water and dust were performed after each test.

SUMMARY OF ENCAPSULATION TESTS ACCORDING TO IEC 60 529: 2013:

Conclusion of the IP65 / IP66/ IP67 / IP68 tests: PASS

The test was in compliance with the requirements in the standard IEC 60 529 Ed 2.2: (2013).